

# Annual Environmental Report

2020



Mooncoin

D0145-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 MOONCOIN WWTP - 2020 - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - MOONCOIN WWTP - 2020
  - 2.1.2 EFFLUENT MONITORING SUMMARY - MOONCOIN WWTP - 2020 -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR MOONCOIN WWTP - 2020
  - 2.1.5 SLUDGE/OTHER INPUTS TO MOONCOIN WWTP - 2020

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

## 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2020 AER

This Annual Environmental Report has been prepared for D0145-01, Mooncoin, in Kilkenny in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

N/A

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Mooncoin WWTP - 2020 with a Plant Capacity PE of 2800, the treatment type is 2 - Secondary treatment

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1500D0145SW001	Mooncoin WWTP - 2020	Treated	Compliant	N/A

## 1.4 LICENCE SPECIFIC REPORTING INCLUDED IN AER

Assessment / Report	Included in AER
There are no Licence Specific Reports included in the AER.	

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 MOONCOIN WWTP - 2020 - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - MOONCOIN WWTP - 2020

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	12	890	372.5
BOD, 5 days with Inhibition (Carbonaceo mg/l	12	264	128.65
Total Phosphorus (as P) mg/l	12	10.2	4.9
Total Nitrogen mg/l	12	63.4	36.15
Suspended Solids mg/l	12	868	197.35
Hydraulic Capacity	N/A	2599	436

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1500D0145SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	12	N/A	N/A	31.66	Pass
<b>Suspended Solids mg/l</b>	35	87.5	N/A	12	1	N/A	11.78	Pass
<b>BOD, 5 days with Inhibition (Carbonaceo mg/l</b>	25	50	N/A	12	N/A	N/A	6.17	Pass
<b>Total Oxidised Nitrogen (as N) mg/l</b>	15	18	N/A	12	N/A	N/A	4.3	Pass
<b>Ammonia-Total (as N) mg/l</b>	10	12	N/A	12	N/A	N/A	0.07	Pass
<b>pH pH units</b>	9	9	N/A	12	N/A	N/A	7.41	Pass
<b>Total Phosphorus (as P) mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	1.64	
<b>Total Nitrogen mg/l</b>	N/A	N/A	N/A	12	N/A	N/A	5.5	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
ortho-Phosphate (as P) - unspecified mg/l	N/A	N/A	N/A	12	N/A	N/A	1.4	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

### Cause of Exceedance(s):

Not applicable

### Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1500D0145SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	248789, 115586	TW31002103SR5003	No	No	No	No	Poor



Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Downstream	251740, 112535	TW31002103SR5005	No	No	No	No	Poor

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**

### Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

The discharge from the wastewater treatment plant does not have an observable impact on the water quality.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - MOONCOIN WWTP - 2020

### 2.1.4.1 Treatment Efficiency Report - Mooncoin WWTP - 2020

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	32318	1230	96
cBOD	21069	644	97
TP	802	171	79

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TN	5921	574	90
COD	61002	3304	95

Note: The above data is based on sample results for the number of dates reported

#### **2.1.4.2 Treatment Capacity Report Summary - Mooncoin WWTP - 2020**

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

<b>Mooncoin WWTP - 2020</b>	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	1890
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	630
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	2599
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	436
<b>Organic Capacity (PE) - As Constructed</b>	2800
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	1374
<b>Organic Capacity (PE) - Remaining</b>	1426
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - MOONCOIN WWTP - 2020

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>There is no Sludge and Other Input data for the Treatment Plant included in the AER.</b>							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2020.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Abatement Equipment offline</b>	Adverse Weather	1	No	Yes

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2020	1
Number of Incidents reported to the EPA via EDEN in 2020	1
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow	Irish Grid Ref.	Included in Schedule A4 of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2020 (No. of events)	Total volume discharged in 2020 (m3)	Monitoring Status
<b>SWO02</b>	250766,116412	Yes	Low	Not yet Assessed	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	N/A
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>There are no Specified Improvement Programmes for this Agglomeration.</b>							

A summary of the status of any improvements identified by under Condition 5.2 is included below.

### 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>There are no Improvements Programme for this Agglomeration.</b>				

### 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Table.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides list of the various reports required for this agglomeration and a brief summary of their recommendations.

5.a Licence Specific Reports Summary Table

Licence Specific Report	Required by licence	Year included in AER	Included in this AER	Reference to relevant section of AER
Priority Substances Assessment	Yes	2015	No	

### 5.1 PRIORITY SUBSTANCES ASSESSMENT

The Priority Substances Assessment Report has been included in the AER 2015



## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for consideration of a Technical Amendment / Review of the licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	No

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 24/03/2021

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Katherine Walshe

Acting Head of Environmental Regulation.

# 7 APPENDIX

Appendix
Appendix 7.1 - Ambient monitoring summary

**Western Mainstem WWP 2014-15**

MonitoringStation	ParameterCode	Methodology	MonitoringStationCode	MonitoringStationName	MonitoringStationType	MonitoringStationSubLocation	SampleCode	SampleDate	SampleMethod	ParameterName	ParameterUnitOrCode	ParameterReference	Result	Threshold	Resulting	UnitOfReference	ResultResult	ResultThreshold	ResultingScore	ResponseTime
WMA01	15	100	0505	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Ammonia Total (as N)	mg/l	nil/grams per litre	0.041	0%	0.01	0.041	0%	0.01
WMA01	15	100	0510	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Chlorophyll	mg/l	Micrograms per litre	25	0%	1	25	0%	1
WMA01	15	100	0515	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Dissolved Oxygen	% Saturation	Percentage Saturation	87	0%	87	87	0%	87
WMA01	15	100	0520	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Salinity	PSU	Practical salinity units	0.3	0%	0.1	0.3	0%	0.1
WMA01	15	100	0525	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	SS (4.75mm Clotted)	mg/l	nil/grams per litre	1.7	0%	1	1.7	0%	1
WMA01	15	100	0530	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	SS (as TSS)	mg/l	nil/grams per litre	0.35	0%	0.1	0.35	0%	0.1
WMA01	15	100	0535	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Total Suspended Solids	mg/l	nil/grams per litre	2.3	0%	0.1	2.3	0%	0.1
WMA01	15	100	0540	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Temperature	°C	Degrees centigrade	16.6	0%	16.6	16.6	0%	16.6
WMA01	15	100	0545	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Dissolved	mg/l	nil/grams per litre	2.3	0%	0.1	2.3	0%	0.1
WMA01	15	100	0550	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Chlorophyll	mg/l	Micrograms per litre	0.3	0%	0.1	0.3	0%	0.1
WMA01	15	100	0555	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Total Dissolved Nitrogen (as N)	mg/l	nil/grams per litre	2.1	0%	0.2	2.1	0%	0.2
WMA01	15	100	0600	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	Transparency	m	Meters	0.4	0%	0.4	0.4	0%	0.4
WMA01	15	100	0605	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	pH units		pH units	8.3	0%	7	8.3	0%	7
WMA01	15	100	0610	Transboundary	F01102102050003	18340 - Soot Estuary at Redwood Quay	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Depth Composite	TOR (as MPDC)	mg/l	nil/grams per litre	0.3	0%	0	0.3	0%	0

**Western Mainstem WWP 2014-15**

MonitoringStation	ParameterCode	Methodology	MonitoringStationCode	MonitoringStationName	MonitoringStationType	MonitoringStationSubLocation	SampleCode	SampleDate	SampleMethod	ParameterName	ParameterUnitOrCode	ParameterReference	Result	Threshold	Resulting	UnitOfReference	ResultResult	ResultThreshold	ResultingScore	ResponseTime
WMA01	15	100	0615	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	Ammonia Total (as N)	mg/l	nil/grams per litre	0.027	0%	0.01	0.027	0%	0.01
WMA01	15	100	0620	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	Chlorophyll	mg/l	Micrograms per litre	30	0%	1	30	0%	1
WMA01	15	100	0625	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	Dissolved	mg/l	Micrograms per litre	1.5	0%	0.5	1.5	0%	0.5
WMA01	15	100	0630	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	Dissolved Oxygen	% Saturation	Percentage Saturation	82	0%	7	82	0%	7
WMA01	15	100	0635	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	Salinity	PSU	Practical salinity units	0.2	0%	0.05	0.2	0%	0.05
WMA01	15	100	0640	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	SS (4.75mm Clotted)	mg/l	nil/grams per litre	0.21	0%	0.1	0.21	0%	0.1
WMA01	15	100	0645	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	SS (as TSS)	mg/l	nil/grams per litre	0.3	0%	0.1	0.3	0%	0.1
WMA01	15	100	0650	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	SS (as TSS)	mg/l	nil/grams per litre	0.5	0%	0.1	0.5	0%	0.1
WMA01	15	100	0655	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	Temperature	°C	Degrees centigrade	16.6	0%	16.6	16.6	0%	16.6
WMA01	15	100	0660	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	Temperature	°C	Degrees centigrade	16.6	0%	16.6	16.6	0%	16.6
WMA01	15	100	0665	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	Total Dissolved Nitrogen (as N)	mg/l	nil/grams per litre	2	0%	0.1	2	0%	0.1
WMA01	15	100	0670	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	Dissolved Oxygen	% Saturation	Percentage Saturation	80	0%	1	80	0%	1
WMA01	15	100	0675	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	Transparency	m	Meters	0.4	0%	0.4	0.4	0%	0.4
WMA01	15	100	0680	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	Salinity	PSU	Practical salinity units	0.1	0%	0.01	0.1	0%	0.01
WMA01	15	100	0685	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	Salinity	PSU	Practical salinity units	0.1	0%	0.1	0.1	0%	0.1
WMA01	15	100	0690	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	Salinity	PSU	Practical salinity units	0.8	0%	0.1	0.8	0%	0.1
WMA01	15	100	0695	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	Salinity	PSU	Practical salinity units	0.8	0%	0.1	0.8	0%	0.1
WMA01	15	100	0700	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	Total Dissolved Nitrogen (as N)	mg/l	nil/grams per litre	1.1	0%	0.1	1.1	0%	0.1
WMA01	15	100	0705	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Bottom	Chlorophyll	mg/l	Micrograms per litre	1.1	0%	1	1.1	0%	1
WMA01	15	100	0710	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	pH units		pH units	8.3	0%	7	8.3	0%	7
WMA01	15	100	0715	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	pH units		pH units	8.3	0%	7	8.3	0%	7
WMA01	15	100	0720	Transboundary	F01102102050005	18310 - Soot Estuary at Soot Lodge	FWMA01	Western City & County Council	20-20045	08/07/2010	Total Surface	Transparency	m	Meters	0.4	0%	0.4	0.4	0%	0.4