

Annual Environmental Report

2021



Tyrellspass

D0099-01

CONTENTS

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

- 2.1 TYRELLSPASS WWTP - TREATED DISCHARGE
 - 2.1.1 INFLUENT SUMMARY - TYRELLSPASS WWTP
 - 2.1.2 EFFLUENT MONITORING SUMMARY - TYRELLSPASS WWTP -
 - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
 - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR TYRELLSPASS WWTP
 - 2.1.5 SLUDGE/OTHER INPUTS TO TYRELLSPASS WWTP

3 COMPLAINTS AND INCIDENTS

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
 - 3.2.1 SUMMARY OF INCIDENTS
 - 3.2.2 SUMMARY OF OVERALL INCIDENTS

4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
 - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
 - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
 - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

5 LICENCE SPECIFIC REPORTS

- 5.1 SMALL STREAM RISK SCORE ASSESSMENT

6 CERTIFICATION AND SIGN OFF

- 6.1 SUMMARY OF AER CONTENTS

7 APPENDIX

- 7.1 SMALL STREAM RISK SCORE ASSESSMENT

Rev 1: Unaccredited Effluent samples removed from the Effluent Summary Table and replaced with accredited samples

1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2021 AER

This Annual Environmental Report has been prepared for D0099-01, Tyrellspass, in Westmeath in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

It is proposed to replace the FBDA system by Q4 2022.

1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- TYRELLSPASS WWTP with a Plant Capacity PE of 2000, the treatment type is 3P - Tertiary P removal.

1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF3200D0099SW001	TYRELLSPASS WWTP	Treated	Compliant	N/A

1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

Small Stream Risk Score Assessment

2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

2.1 TYRELLSPASS WWTP - TREATED DISCHARGE

2.1.1 INFLUENT MONITORING SUMMARY - TYRELLSPASS WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Ammonia-Total (as N) mg/l	12	59	25
BOD - 5 days (Total) mg/l	12	476	166
Total Phosphorus (as P) mg/l	12	11	4.18
Total Nitrogen mg/l	12	82	34
COD-Cr mg/l	12	977	457.84
Suspended Solids mg/l	12	483	203.64
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	12	462	184
pH pH units	12	7.90	7.46
ortho-Phosphate (as P) - unspecified mg/l	12	5.76	2.50
Hydraulic Capacity	N/A	740	222

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'. The design of the wastewater treatment plant allows for peak values and therefore the peak loads have not impacted on compliance with Emission Limit Values.

2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF3200D0099SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included ^{Note 1}	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
COD-Cr mg/l	125	250	N/A	12	N/A	N/A	28	Pass
Suspended Solids mg/l	35	88	N/A	12	N/A	N/A	11	Pass
pH pH units	6.00	9.00	N/A	12	N/A	N/A	7.43	Pass
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	8.00	16	N/A	12	2	N/A	3.86	Pass
Ammonia-Total (as N) mg/l	0.500	1.00	N/A	12	N/A	N/A	0.055	Pass
ortho-Phosphate (as P) - unspecified mg/l	0.260	0.520	N/A	12	N/A	N/A	0.038	Pass

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included ^{Note 1}	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
Total Phosphorus (as P) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.216	
Nitrite (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	0.079	
Total Oxidised Nitrogen (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	12	
Total Nitrogen mg/l	N/A	N/A	N/A	12	N/A	N/A	15	
Conductivity @20°C µS/cm	N/A	N/A	N/A	12	N/A	N/A	579	
Nitrate (as N) mg/l	N/A	N/A	N/A	12	N/A	N/A	11	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

Cause of Exceedance(s):

Not applicable

Significance of Results:

The WWTP is compliant with the ELV's set in the Wastewater Discharge Licence.

2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF3200D0099SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	240896, 238378	RS25T070150	No	No	No	No	Moderate
Downstream	238455, 239453	RS25T070680	No	No	No	No	Moderate

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS25T070150	1.30	RS25T070680	1.31	1.50	0.6
Ammonia-Total (as N) mg/l	RS25T070150	0.044	RS25T070680	0.072	0.065	42.7
ortho-Phosphate (as P) - unspecified mg/l	RS25T070150	0.026	RS25T070680	0.034	0.035	22
Suspended Solids mg/l	RS25T070150	13	RS25T070680	3.54	N/A	
BOD, 5 days with Inhibition (Carbonaceous BOD) mg/l	RS25T070150	1.41	RS25T070680	1.41	N/A	

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
Temperature °C	RS25T070150	11	RS25T070680	11	N/A	
Total Phosphorus (as P) mg/l	RS25T070150	0.063	RS25T070680	0.071	N/A	
Dissolved Oxygen % Saturation	RS25T070150	87	RS25T070680	82	N/A	
pH pH units	RS25T070150	7.90	RS25T070680	7.88	N/A	
COD-Cr mg/l	RS25T070150	20	RS25T070680	33	N/A	
Total Nitrogen mg/l	RS25T070150	4.86	RS25T070680	3.64	N/A	
Dissolved Oxygen mg/l	RS25T070150	9.56	RS25T070680	9.16	N/A	
Conductivity @20°C µS/cm	RS25T070150	681	RS25T070680	604	N/A	

Significance of Results:

The WWTP discharge was compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the downstream monitoring location - The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in BOD, Ammonia & Ortho-P concentrations downstream of the effluent discharge is noted.

A deterioration in water quality has been identified, however it is not known if it or is not caused by the WWTP.

As per the 3rd Cycle Lower Shannon (Brosna) Catchment Report (HA 25A), Agriculture is the significant pressure on the At Risk Brosna_050 waterbody. The Tyrellspass WWTP, although listed on Cycle 2 as a significant pressure, has been removed from the list of significant pressures in the Cycle 3 report.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

2.1.4 OPERATIONAL PERFORMANCE SUMMARY - TYRELLSPASS WWTP

2.1.4.1 Treatment Efficiency Report - TYRELLSPASS WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
SS	18644	1149	94
TN	3102	1507	51
TP	382	22	94
cBOD	16846	388	98
COD	41917	2855	93

Note: The above data is based on sample results for the number of dates reported

2.1.4.2 Treatment Capacity Report Summary - TYRELLSPASS WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

TYRELLSPASS WWTP	
Peak Hydraulic Capacity (m ³ /day) - As Constructed	1350
DWF to the Treatment Plant (m ³ /day)	450
Current Hydraulic Loading - annual max (m ³ /day)	740

TYRELLSPASS WWTP	
Average Hydraulic loading to the Treatment Plant (m ³ /day)	221.92
Organic Capacity (PE) - As Constructed	2000
Organic Capacity (PE) - Collected Load (peak week) ^{Note1}	559
Organic Capacity (PE) - Remaining	1441
Will the capacity be exceeded in the next three years? (Yes/No)	No

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

2.1.5 SLUDGE / OTHER INPUTS - TYRELLSPASS WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

3 COMPLAINTS AND INCIDENTS

3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2021.			

3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Irish Water but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	Yes
Abatement Equipment offline	Plant or equipment breakdown at WWTP	1	No	No
Spillage	Plant or equipment breakdown at WWTP	1	No	No

3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2021	3
Number of Incidents reported to the EPA via EDEN in 2021	3
Explanation of any discrepancies between the two numbers above	N/A

4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2021 (No. of events)	Total volume discharged in 2021 (m ³)	Monitoring Status
SW2	240821, 238268	Yes	Low	Meeting	Unknown	Unknown	Not Monitored

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m ³)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	N/A

4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
D0099-SIP:01	Waste Water treatment plant and ancillary works	C	01/12/2014	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
No additional improvements planned at this time.				

4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2012	No
Small Stream Risk Score Assessment	Yes	2022	Yes

5.1 SMALL STREAM RISK SCORE ASSESSMENT

The Small Stream Risk Score Assessment Report is included in Appendix 7.2 - Small Stream Risk Score Assessment. A summary of the findings of this report is included below.

Parameter	Value
Condition 5 Improvement Programme Reference	N/A
Does SSRS indicate discharges are posing a pollution risk?	No
Downstream SSRS Water Quality Risk	At Risk
SSRS Required?	Yes
Upstream SSRS Water Quality Risk	At Risk
What is Downstream SSRS?	4

Parameter	Value
What is Upstream SSRS?	1.6
Does improvement programme include any procedural and/or infrastructural works?	N/A

6 CERTIFICATION AND SIGN OFF

6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e., have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Has a Technical amendment/licence review application been submitted to the Agency by IW?	No
List reason e.g., additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g., changes to monitoring requirements	Ambient Monitoring Location Changes
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 12/04/2022

This AER has been produced by Irish Water's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Katherine Walshe

Acting Head of Environmental Regulation.

7 APPENDIX

Appendix

Appendix 7.1 - Small Stream Risk Score Assessment

River:	Code:	Date: 11/10/21	Time: 2:30 PM
Station no.	Location: Tyrrelleppis 4/5		Grid (6 figure):
Field Chemistry		Stream Order:	Stream flow: Riffle Riffle/Glide Slow flow
DO%	9.6	Modifications: <input checked="" type="checkbox"/> N Canalised-widened-bank erosion-arterial drainage <i>culverted</i>	
DO mg/l	10.47	Dominant Types:	
Temp (°C)	12.3	Bedrock	
Conductivity		Boulder (>128mm)	
pH		Cobble (32-128mm)	
Bank width (cm)	1m	Gravel (8-32mm)	
Wet width (cm)	0.5m	Fine Gravel (2-8mm)	
Avg Depth (cm)	10cm	Sand (0.25-2mm)	
Staff gauge		Silt (<0.25mm)	
Velocity	Colour	Slope: Low - Medium - High - Very High	Shading: High - Moderate - Low - None
Torrential	None	Geology: Calcareous-Siliceous-Mixed <i>solid rock</i>	Cattle access: <input checked="" type="checkbox"/> upstream - <input checked="" type="checkbox"/> downstream or N
Fast	Slight	Substratum Condition: Calcareous-Compacted-Loose - Normal	Photo: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N
Moderate	Moderate	Substratum: Stony bottom - Muddy bottom - Mud over stones	
Slow	High	Degree of siltation: Clean - Slight - Moderate - Heavy	
Very slow		Depth of mud: None - <1cm - 1-5cm - 5-10cm - >10cm	
Clarity	Discharge	Litter: None - Present - Moderate - Abundant	
Very clear	Flood	Filamentous Algae: None - Present - Moderate - Abundant	Sewage Fungus: None - Present - Moderate - Abundant
Slightly turbid	Low	Main land use u/s: Pasture Urban Bog Tillage Forestry Other	Sample retained: Y / <input checked="" type="checkbox"/> N
Highly turbid	Very Low		Sampled in Minutes: Pond net x <i>2 min</i>
	Dry		Stone wash x —
	Recent Flood		Weed sweep x

General Comments:

Macroinvertebrate Composition

The macroinvertebrates are divided into the following 5 specific groups:

- Group 1 = Ephemeroptera (3-tails) - note that tails may be damaged during sampling
- Group 2 = Plecoptera (2-tails) - note that tails may be damaged during sampling
- Group 3 = Trichoptera
- Group 4 = G.O.L.D (Gastropoda, Oligochaeta and Diptera)
- Group 5 = *Asellus*
- Calculate the total number of taxa and relative abundance of each macroinvertebrate group below: (Abundance - Ab)

Relative Abundance






1-5	1
6-20	2
21-50	3
51-100	4
101+	5

Ephemeroptera:		Plecoptera:	
<i>Ecdyonurus</i> Ab		<i>Leuctra</i> Ab	
<i>Rhythrogena</i> Ab		<i>Isoperla</i> Ab	
<i>Heptagenia</i> Ab		<i>Protonemura</i> Ab	
<i>Ephemérella</i> Ab		<i>Amphinemura</i> Ab	
<i>Baetis</i> Ab		<i>Perla</i> Ab	
<i>Paraleptophlebia</i> Ab		<i>Dinocras</i> Ab	
<i>Ephemera danica</i> Ab		Other Plecop Ab	
Other Ephem Ab		Other Plecop Ab	
Total no. of taxa 0	Total Relative Abundance 0	Total no. of Taxa 0	Total Relative Abundance 0
Trichoptera:		G.O.L.D:	
Hydropsychidae Ab		<i>Lymnaea</i> (G) Ab	
Polycentropodidae Ab		<i>Potamopyrgus</i> (G) Ab (1)	
<i>Rhyacophila</i> Ab		<i>Planorbis</i> (G) Ab (1)	
Philopotamidae Ab		<i>Ancylus</i> (G) Ab	
Limnephilidae Ab (1)		<i>Physa</i> (G) Ab	
Sericostomatidae Ab (1)		<i>Lumbriculus</i> (OI) Ab	
Glossosomatidae Ab		<i>Eisenella</i> (OI) Ab (1)	
Lepidostomatidae Ab		Tubificidae (OI) Ab (2)	
Other Trichoptera Ab			
Total no. of Taxa 2	Total Relative Abundance 2	Total no. of Taxa 8	Total Relative Abundance 9
		Chironomidae (D) Ab	
		<i>Chironomus</i> (D) Ab	
		Simuliidae (D) Ab (1)	
		<i>Dicranota</i> (D) Ab	
		Tipulidae (D) Ab (1)	
		Ceratopogonidae (D) Ab (1)	
		Other GOLD Ab (1)	
		<i>Asellus:</i>	
		Absent	
		Few/Low	
		Common/Numerous	
		NOTE: <i>Asellus</i> must be recorded as absent if none are found	

NOTE *Baetis* is an Ephemeropteran and is the most commonly occurring invertebrate genus in streams in Ireland. It is vital that *Baetis* is not counted in SSRS. See Appendix B for more details on how to identify *Baetis*.

Gammarus Abundant

Step 1. Calculate the Index Score by circling the appropriate box representing the total number of taxa and the total abundance calculated from *each macroinvertebrate group* calculated from page 1 of the recording sheet and enter in to the boxes in Step 2.



Step 2

a) Index Score Group 1	0
b) Index Score Group 2	0
c) Index Score Group 3	2
d) Index Score Group 4	0
e) Index Score Group 5	2

Step 3. Calculate the Total Index Score, the Average Index Score and the SSR Score using the boxes below

Total Index Score (TIS) sum (a+b+c+d+e) **4**

Average Index Score (AIS) TIS/5 (5 for 5 groups) **0.8**

SSR Score (AIS x 2) **1.6**

Step 4. Assess the stream by comparing the final SSR score with the categories below and tick the appropriate box

> 7.25 Probably not at risk

> 6.5 - 7.25 Indeterminate Stream may be at risk

< 6.5 Stream at risk

Surveyor (signed): E. Wlelelan Name (print): _____ Date: 10 / 10 / 21

Tyrells pass d/s

River:		Code:	Date: 11/10/21	Time: 3:30
Station no.:		Location:		Grid (6 figure):
Field Chemistry		Stream Order:		Stream flow:
DO%	91.5	Modifications: <input checked="" type="checkbox"/> Canalised-widened-bank erosion-arterial drainage		Riffle
DO mg/l	9.95	Dominant Types:		Riffle/Gilde
Temp (°C)	11.7	Bedrock		Slow flow
Conductivity		Boulder (>128mm)		
pH		Cobble (32-128mm)		
Bank width (cm)	6M	Gravel (8-32mm)		
Wet width (cm)	3M	Fine Gravel (2-8mm)		
Avg Depth (cm)	0.6m	Sand (0.25-2mm)		
Staff gauge		Silt (<0.25mm)		
Velocity	Colour	Slope: <input checked="" type="checkbox"/> Low - <input type="checkbox"/> Medium - <input type="checkbox"/> High - <input type="checkbox"/> Very High		Shading: High - <input checked="" type="checkbox"/> Moderate - <input type="checkbox"/> Low - <input type="checkbox"/> None
Torrential	None	Geology: Calcareous-Siliceous-Mixed		Cattle access Y: upstream - downstream of N
Fast	Slight	Substratum Condition: Calcareous-Compacted		
Moderate	Moderate	Loose <input checked="" type="checkbox"/> Normal		
Slow	High	Substratum:		
Very slow		Stoney bottom-Muddy bottom-Mud over stones		Photo: <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N
Clarity	Discharge	Degree of siltation: Clear <input checked="" type="checkbox"/> Slight <input type="checkbox"/> Moderate <input type="checkbox"/> Heavy		
Very clear	Flood	Depth of mud: None <input checked="" type="checkbox"/> <1cm <input type="checkbox"/> 1-5cm <input type="checkbox"/> 5-10cm <input type="checkbox"/> >10cm		
Clear	Normal	Litter: None <input checked="" type="checkbox"/> Present - Moderate - Abundant		
Slightly turbid	Low	Filamentous Algae:		Sewage Fungus:
Highly turbid	Very Low	None <input checked="" type="checkbox"/> Present - Moderate - Abundant		None <input checked="" type="checkbox"/> Present - Moderate - Abundant
	Dry	Main land use u/s:		Sampled in Minutes:
	Recent Flood	Pasture <input checked="" type="checkbox"/> Urban		Pond net x <input checked="" type="checkbox"/>
		Bog <input type="checkbox"/> Tillage		Stone wash x <input type="checkbox"/>
		Forestry <input type="checkbox"/> Other		Weed sweep x <input type="checkbox"/>

General Comments:

Macroinvertebrate Composition

The macroinvertebrates are divided into the following 5 specific groups:

- Group 1 = Ephemeroptera (3-tails) - note that tails may be damaged during sampling
- Group 2 = Plecoptera (2-tails) - note that tails may be damaged during sampling
- Group 3 = Trichoptera
- Group 4 = G.O.L.D (Gastropoda, Oligochaeta and Diptera)
- Group 5 = Asellus
- Calculate the total number of taxa and relative abundance of each macroinvertebrate group below: (Abundance - Ab)

Relative Abundance

1-5	1
6-20	2
21-50	3
51-100	4
101+	5






Ephemeroptera:		Plecoptera:	
<i>Ecdyonurus</i> Ab		<i>Leuctra</i> Ab	
<i>Rhythrogena</i> Ab		<i>Isoperla</i> Ab	
<i>Heptagenia</i> Ab		<i>Protonemura</i> Ab	
<i>Ephemerella</i> Ab		<i>Amphinemura</i> Ab	
<i>Baetis</i> Ab		<i>Perlodes</i> Ab	
<i>Paraleptophlebia</i> Ab		<i>Dinocras</i> Ab	
<i>Ephemerella danica</i> Ab		Other Plecop Ab	
Other Ephem Ab		Other Plecop Ab	
Total no. of taxa	0	Total no. of Taxa	0
Total Relative Abundance	0	Total Relative Abundance	0
Trichoptera:	G.O.L.D:	Chironomidae (D) Ab	Asellus:
Hydropsychidae Ab	<i>Lymnaea</i> (G) Ab	<i>Chironomus</i> (D) Ab	Absent <input checked="" type="checkbox"/>
Polycentropodidae Ab	<i>Potamopyrgus</i> (G) Ab	Simuliidae (D) Ab	Few/Low
<i>Rhyacophila</i> Ab	<i>Planorbis</i> (G) Ab	<i>Dicranota</i> (D) Ab	Common/Numerous
Philopotamidae Ab	<i>Ancylus</i> (G) Ab	Tipulidae (D) Ab	
Limnephilidae Ab	<i>Physa</i> (G) Ab	Ceratopogonidae (D) Ab	
Sericostomatidae Ab	<i>Lumbriculus</i> (OI) Ab	Other GOLD Ab	NOTE: Asellus must be recorded as absent if none are found
Glossosomatidae Ab	<i>Eisenella</i> (OI) Ab		
Lepidostomatidae Ab	Tubificidae (OI) Ab		
Other Trichoptera Ab			
Total no. of Taxa	1	Total no. of Taxa	4
Total Relative Abundance	1	Total Relative Abundance	6

NOTE *Baetis* is an Ephemeropteran and is the most commonly occurring Invertebrate genus in streams in Ireland. It is vital that *Baetis* is not counted in SSRS. See Appendix B for more details on how to identify *Baetis*.

Gammarus abundant

Baetis present.

Step 1. Calculate the Index Score by circling the appropriate box representing the total number of taxa and the total abundance calculated from *each macroinvertebrate group* calculated from page 1 of the recording sheet and enter in to the boxes in Step 2.



Step 2

- a) Index Score Group 1
- b) Index Score Group 2
- c) Index Score Group 3
- d) Index Score Group 4
- e) Index Score Group 5

Step 3. Calculate the Total Index Score, the Average Index Score and the SSR Score using the boxes below

Total Index Score (TIS) sum (a+b+c+d+e)

Average Index Score (AIS) TIS/5 (5 for 5 groups)

SSR Score (AIS x 2)

Step 4. Assess the stream by comparing the final SSR score with the categories below and tick the appropriate box

> 7.25 Probably not at risk

> 6.5 – 7.25 Indeterminate Stream may be at risk

< 6.5 Stream at risk

Surveyor (signed): E. Whelan Name (print): _____ Date: 11 / 10 / 21