

# Annual Environmental Report

2022



Drogheda

D0041-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 DROGHEDA WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - DROGHEDA WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - DROGHEDA WWTP
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR DROGHEDA WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO DROGHEDA WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

- 5.1 PRIORITY SUBSTANCES ASSESSMENT

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

- 7.1 AMBIENT MONITORING SUMMARY

# 1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER

This Annual Environmental Report has been prepared for D0041-01, Drogheda, in Louth in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## 1.1 ANNUAL STATEMENT OF MEASURES

A summary of any improvements undertaken is provided where applicable.

Works are currently ongoing on the anaerobic digester.

## 1.2 TREATMENT SUMMARY

The agglomeration is served by a wastewater treatment plant(s)

- Drogheda WWTP with a Plant Capacity PE of 101600, the treatment type is 3NP - Tertiary N&P removal .

## 1.3 ELV OVERVIEW

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
<b>TPEFF2100D0041SW001</b>	Drogheda WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l ortho-Phosphate (as P) - unspecified mg/l Suspended Solids mg/l

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report

**There are no Licence Specific Reports included in this AER.**

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 DROGHEDA WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - DROGHEDA WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
Total Nitrogen mg/l	28	73	25
COD-Cr mg/l	28	1625	678
Suspended Solids mg/l	28	924	439
Total Phosphorus (as P) mg/l	28	19	9.36
BOD, 5 days with Inhibition (Carbonaceous) mg/l	28	336	138
Hydraulic Capacity	N/A	47520	25675

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is less than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF2100D0041SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included <sup>Note 1</sup>	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	28	N/A	N/A	33	Pass
<b>Suspended Solids mg/l</b>	25	62	N/A	28	4	N/A	13	Fail
<b>BOD, 5 days with Inhibition (Carbonaceous) mg/l</b>	20	40	N/A	28	N/A	N/A	2.89	Pass
<b>Total Nitrogen mg/l</b>	15	18	N/A	28	2	N/A	11	Pass
<b>pH pH units</b>	6.00	9.00	N/A	28	N/A	N/A	7.70	Pass
<b>Ammonia-Total (as N) mg/l</b>	2.00	2.40	N/A	28	11	10	2.15	Fail
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	1.50	1.80	N/A	28	1	1	0.587	Fail
<b>Total Phosphorus (as P) mg/l</b>	N/A	N/A	N/A	28	N/A	N/A	0.798	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Plant or equipment maintenance at WWTP, Inadequate operational procedures/training & WWTP upgrade required to meet Ammonia ELV.

### Significance of Results:

The WWTP is non compliant with the ELV's set in the Wastewater Discharge Licence. The impact on receiving waters is assessed further in Section 2.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF2100D0041SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Status
Upstream	311724, 275841	TW21001002BE1005	No	No	No	No	Moderate
Downstream	313053, 276227	TW21001002BE1006	Yes	No	No	No	Moderate

The results for ambient results and / or additional monitoring data sets are included in the **Appendix 7.1 - Ambient monitoring summary**.

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence for the following: Ammonia-Total (as N), ortho-Phosphate (as P) - unspecified and Suspended Solids.

The ambient monitoring results meet the required EQS. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia and TON concentrations downstream of the effluent discharge is noted.

Agriculture & the Drogheda WWTP are cited as significant pressures impacting the Boyne Estuary transitional waterbody in the 3rd Cycle Draft Boyne Catchment Report (HA 07).

Based on the effluent compliance results, the discharge from the wastewater treatment plant may be having an observable negative impact on the Water Framework Directive status downstream of the WWTP. It should be noted however that the current WFD status is Moderate both upstream and downstream of the WWTP.

It is not considered that the discharge from the wastewater treatment plant is having an observable negative impact on any downstream bathing water areas.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - DROGHEDA WWTP

### 2.1.4.1 Treatment Efficiency Report - Drogheda WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
<b>COD</b>	6194930	302195	95
<b>TN</b>	230242	95153	59
<b>TP</b>	85469	7218	92
<b>SS</b>	4011741	117009	97
<b>cBOD</b>	1261954	26111	98

Note: The above data is based on sample results for the number of dates reported.



### 2.1.4.2 Treatment Capacity Report Summary - Drogheda WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Drogheda WWTP	
<b>Peak Hydraulic Capacity (m<sup>3</sup>/day) - As Constructed</b>	84550
<b>DWF to the Treatment Plant (m<sup>3</sup>/day)</b>	67288
<b>Current Hydraulic Loading - annual max (m<sup>3</sup>/day)</b>	47520
<b>Average Hydraulic loading to the Treatment Plant (m<sup>3</sup>/day)</b>	25675
<b>Organic Capacity (PE) - As Constructed</b>	101600
<b>Organic Capacity (PE) - Collected Load (peak week)<sup>Note1</sup></b>	84606
<b>Organic Capacity (PE) - Remaining</b>	16994
<b>Will the capacity be exceeded in the next three years? (Yes/No)</b>	No

Note 1: Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - DROGHEDA WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
<b>Other</b>	12920.1	Weight (Tonnes)	157	0.14	Yes	Yes	Yes
<b>Industrial / Commercial Sludge</b>	18210	Weight (Tonnes)	222	0.2	Yes	Yes	Yes
<b>Domestic /Septic Tank Sludge</b>	741.3	Weight (Tonnes)	9	0.01	Yes	Yes	Yes
<b>Landfill Leachate (delivered by tanker)</b>	22945.92	Weight (Tonnes)	279	0.26	Yes	Yes	Yes

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
<b>There were no relevant environmental complaints in 2022.</b>			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Other</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Abatement Equipment offline</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Abatement Equipment offline</b>	Plant or equipment maintenance at WWTP	1	No	Yes
<b>Breach of ELV</b>	WWTP upgrade required to meet ELV	1	Yes	No
<b>Breach of ELV</b>	Plant or equipment maintenance at WWTP	1	No	Yes
<b>Breach of ELV</b>	Inadequate Operational Procedures / Training	1	No	No
<b>Breach of ELV</b>	Inadequate Operational Procedures / Training	1	No	No
<b>Spillage</b>	Plant or equipment breakdown at WWTP	1	No	Yes
<b>Spillage</b>	Inadequate Operational Procedures / Training	1	No	Yes
<b>Uncontrolled release</b>	Network Infrastructure	1	No	Yes
<b>Uncontrolled release</b>	SWO exceptional rainfall and overflow expected	1	No	Yes
<b>Uncontrolled release</b>	SWO exceptional rainfall and overflow expected	1	No	Yes
<b>Uncontrolled release</b>	Broken Sewer Pipe	1	No	Yes

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2022	19
Number of Incidents reported to the EPA via EDEN in 2022	19
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m <sup>3</sup> )	Monitoring Status
SW15	309745 275465	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	310736 275478	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	306422 275105	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW10	308818 274957	Yes	Low Significance	Not Meeting Criteria	Unknown	Unknown	Not Monitored
SW3	310234 275453	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW4	309266 275160	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m <sup>3</sup> )	Monitoring Status
<b>SW5</b>	309037 275017	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW6</b>	308774 274990	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW7</b>	308583 275086	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>SW8</b>	308134 275363	Yes	Medium Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	307637 275457	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	315091 276131	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	TBC
<b>TBC</b>	314640 275509	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	313299 275941	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
<b>TBC</b>	316186 271181	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m <sup>3</sup> )?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	No
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes
Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?	No

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0041-SIP:01</b>	Nutrient removal to meet ELVs as specified in Schedule A	C	30/06/2014	Yes	Works Completed		

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.



## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.

## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
Priority Substances Assessment	Yes	2014	No

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	No
List reason e.g. additional SWO identified	N/A
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	No
List reason e.g. changes to monitoring requirements	N/A
Have these processes commenced?	N/A
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Date: 28/02/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of,

Eleanor Roche

Acting Head of Environmental Regulation.

## 7 APPENDIX

Appendix

**Appendix 7.1 - Ambient Monitoring Summary**

## Drogheda 2022 Ambient Monitoring Data

### Ambient Monitoring Report Summary Table

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish National Grid Reference (Easting, Northing)	EPA Feature Coding Tool code	Receiving Waters Designation (Yes/No)				WFD Status 2016- 2021
			Bathing Water	Drinking Water	FWPM	Shellfish	
Upstream Monitoring Point	E311724 N275841	TW21001002BE1005	No	No	No	No	Moderate
Downstream Monitoring Point	E313053 N276227	TW21001002BE1006	Yes	No	No	No	Moderate

## 2022 Ambient Monitoring Summary

			Ammonia N	Ortho- Phosphate P	Total Suspended Solids	Total Oxidised Nitrogen N	pH	Dissolved Oxygen % Saturation	Biological Oxygen Demand
Station	Station Reference	Sample Date	mg/l	mg/l	mg/l	mg/l	pH units	% Sat.	mg/l
Upstream	TW21001002BE1005	07.03.22	0.04	0.03	15	4.22	8.25	90.1	1.1
Upstream	TW21001002BE1005	20.06.22	0.42	0.04	177	0.12	7.64	82.2	3.8
Upstream	TW21001002BE1005	14.09.22	0.05	0.05	20	1.73	8.2	79	1.7
Upstream	TW21001002BE1005	18.11.22	0.01	0.04	370	0.92	8.17	101.1	4
		<b>Mean</b>	<b>0.13</b>	<b>0.04</b>	<b>145.50</b>	<b>1.75</b>	<b>8.07</b>	<b>88.10</b>	<b>2.65</b>
		<b>95%ile</b>	<b>0.36</b>	<b>0.05</b>	<b>341.05</b>	<b>3.85</b>	<b>8.24</b>	<b>99.45</b>	<b>3.97</b>
			Ammonia N	Ortho- Phosphate P	Total Suspended Solids	Total Oxidised Nitrogen N	pH	Dissolved Oxygen % Saturation	Biological Oxygen Demand
Station	Station Reference	Sample Date	mg/l	mg/l	mg/l	mg/l	pH units	% Sat.	mg/l
Downstream	TW21001002BE1006	07.03.22	0.03	0.03	18	4.25	8.18	91.4	1
Downstream	TW21001002BE1006	20.06.22	0.44	0.04	63	0.12	7.63	78.4	4.5
Downstream	TW21001002BE1006	14.09.22	0.05	0.05	20	1.76	8.02	85.5	1.3
Downstream	TW21001002BE1006	18.11.22	0.02	0.04	304	0.93	8.13	105.5	3.2
		<b>Mean</b>	<b>0.14</b>	<b>0.04</b>	<b>101.25</b>	<b>1.77</b>	<b>7.99</b>	<b>90.20</b>	<b>2.50</b>
		<b>95%ile</b>	<b>0.38</b>	<b>0.05</b>	<b>267.85</b>	<b>3.88</b>	<b>8.17</b>	<b>103.39</b>	<b>4.31</b>

## Seapoint (Louth) Bathing Waters (EPA Beaches.ie)

The Escherichia coli and Intestinal enterococci results for the 2022 sample period are tabled below.

Date	Escherichia coli	Intestinal enterococci	Sample Quality Status
05/09/2022	31	11	Excellent
30/08/2022	63	23	Excellent
29/08/2022	75	32	Excellent
24/08/2022	31	11	Excellent
23/08/2022	10	9	Excellent
16/08/2022	10	2	Excellent
15/08/2022	31	30	Excellent
09/08/2022	41	9	Excellent
08/08/2022	41	8	Excellent
02/08/2022	10	5	Excellent
25/07/2022	691	420	Poor
18/07/2022	<10	1	Excellent
11/07/2022	<10	4	Excellent
04/07/2022	20	<1	Excellent
27/06/2022	20	3	Excellent
20/06/2022	<10	<1	Excellent
13/06/2022	<10	<1	Excellent
07/06/2022	<10	<1	Excellent
01/06/2022	<10	<1	Excellent
23/05/2022	<10	3	Excellent



### **Clogherhead Bathing Waters (EPA Beaches.ie)**

The Escherichia coli and Intestinal enterococci results for the 2022 sample period are tabled below.

<b>Date</b>	<b>Escherichia coli</b>	<b>Intestinal enterococci</b>	<b>Sample Quality Status</b>
05/09/2022	197	80	Excellent
30/08/2022	<10	18	Excellent
29/08/2022	10	3	Excellent
24/08/2022	<10	4	Excellent
23/08/2022	10	10	Excellent
16/08/2022	122	14	Excellent
15/08/2022	31	65	Excellent
09/08/2022	<10	2	Excellent
08/08/2022	<10	1	Excellent
02/08/2022	85	13	Excellent
25/07/2022	<10	29	Excellent
18/07/2022	<10	1	Excellent
11/07/2022	75	4	Excellent
04/07/2022	<10	2	Excellent
27/06/2022	<10	<1	Excellent
20/06/2022	135	3	Excellent
13/06/2022	<10	<1	Excellent
07/06/2022	<10	1	Excellent
01/06/2022	<10	1	Excellent
23/05/2022	10	5	Excellent

### **Laytown/Bettystown Waters (EPA Beaches.ie)**

The Escherichia coli and Intestinal enterococci results for the 2022 sample period are tabled below.

<b>Date</b>	<b>Escherichia coli</b>	<b>Intestinal enterococci</b>	<b>Sample Quality Status</b>
12/09/2022	52	120	Good
05/09/2022	336	180	Good
29/08/2022	10	23	Excellent
22/08/2022	74	58	Excellent
15/08/2022	63	37	Excellent
08/08/2022	62	11	Excellent
02/08/2022	41	26	Excellent
25/07/2022	10	12	Excellent
18/07/2022	<10	1	Excellent
11/07/2022	20	10	Excellent
04/07/2022	20	2	Excellent
27/06/2022	<10	1	Excellent
20/06/2022	<10	<1	Excellent
13/06/2022	<10	4	Excellent
07/06/2022	<10	<1	Excellent
23/05/2022	20	<1	Excellent