

# Annual Environmental Report

2022



Askeaton

D0315-01

## **CONTENTS**

### **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER**

- 1.1 ANNUAL STATEMENT OF MEASURES
- 1.2 TREATMENT SUMMARY
- 1.3 ELV OVERVIEW
- 1.4 LICENSE SPECIFIC REPORT INCLUDED IN AER

### **2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY**

- 2.1 ASKEATON WWTP - TREATED DISCHARGE
  - 2.1.1 INFLUENT SUMMARY - ASKEATON WWTP
  - 2.1.2 EFFLUENT MONITORING SUMMARY - ASKEATON WWTP -
  - 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE -
  - 2.1.4 OPERATIONAL REPORTS SUMMARY FOR ASKEATON WWTP
  - 2.1.5 SLUDGE/OTHER INPUTS TO ASKEATON WWTP

### **3 COMPLAINTS AND INCIDENTS**

- 3.1 COMPLAINTS SUMMARY
- 3.2 REPORTED INCIDENTS SUMMARY
  - 3.2.1 SUMMARY OF INCIDENTS
  - 3.2.2 SUMMARY OF OVERALL INCIDENTS

### **4 INFRASTRUCTURAL ASSESSMENT AND PROGRAMME OF IMPROVEMENTS**

- 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT
  - 4.1.1 SWO IDENTIFICATION AND INSPECTION SUMMARY REPORT
- 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS
  - 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.2 IMPROVEMENT PROGRAMME SUMMARY
  - 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

### **5 LICENCE SPECIFIC REPORTS**

### **6 CERTIFICATION AND SIGN OFF**

- 6.1 SUMMARY OF AER CONTENTS

### **7 APPENDIX**

# **1 EXECUTIVE SUMMARY AND INTRODUCTION TO THE 2022 AER**

This Annual Environmental Report has been prepared for D0315-01, Askeaton, in Limerick in accordance with the requirements of the wastewater discharge licence for the agglomeration. Specified reports where relevant are included as an appendix to the AER.

## **1.1 ANNUAL STATEMENT OF MEASURES**

A summary of any improvements undertaken is provided where applicable.

There was no major capital or operational changes undertaken

## **1.2 TREATMENT SUMMARY**

The agglomeration is served by a wastewater treatment plant(s)

- Askeaton WWTP with a Plant Capacity PE of 550, the treatment type is 1 - Primary treatment .

## **1.3 ELV OVERVIEW**

The overall compliance of the final effluent with the Emission Limit Values (ELVs) is shown below. More detailed information on the below ELV's can be found in Section 2.

Discharge Point Reference	Treatment Plant	Discharge Type	Compliance Status	Parameters failing if relevant
TPEFF1900D0315SW001	Askeaton WWTP	Treated	Non-Compliant	Ammonia-Total (as N) mg/l BOD, 5 days with Inhibition (Carbonaceo mg/l COD-Cr mg/l ortho-Phosphate (as P) - unspecified mg/l Suspended Solids mg/l

## 1.4 LICENCE SPECIFIC REPORTING

Assessment / Report
There are no Licence Specific Reports included in this AER.

## 2 TREATMENT PLANT PERFORMANCE AND IMPACT SUMMARY

### 2.1 ASKEATON WWTP - TREATED DISCHARGE

#### 2.1.1 INFLUENT MONITORING SUMMARY - ASKEATON WWTP

A summary of influent monitoring for the treatment plant is presented below. This monitoring is primarily undertaken in order to determine the overall efficiency of the plant in removing pollutants from the raw wastewater.

Parameters	Number of Samples	Annual Max	Annual Mean
COD-Cr mg/l	6	562	354
BOD, 5 days with Inhibition (Carbonaceo mg/l	6	265	163
Total Phosphorus (as P) mg/l	1	6.02	6.02
Suspended Solids mg/l	6	337	130
Total Nitrogen mg/l	1	51	51
Hydraulic Capacity	N/A	718	252

If other inputs in the form of sludge / leachate are added to the WWTP then these are included in Section 2.1.5 if applicable.

#### Significance of Results:

The annual mean hydraulic loading is less than the peak Treatment Plant Capacity. The annual maximum hydraulic loading is greater than the peak Treatment Plant Capacity. Further details on the plant capacity and efficiency can be found under the sectional 'Operational Performance Summary'.

## 2.1.2 EFFLUENT MONITORING SUMMARY - TPEFF1900D0315SW001

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>COD-Cr mg/l</b>	125	250	N/A	6	4	3	302	Fail
<b>Suspended Solids mg/l</b>	35	87.5	N/A	6	6	3	102	Fail
<b>BOD, 5 days with Inhibition (Carbonaceous) mg/l</b>	25	50	N/A	6	5	4	134	Fail
<b>Ammonia-Total (as N) mg/l</b>	15	18	N/A	6	4	4	24	Fail
<b>pH pH units</b>	9	9	N/A	6	N/A	N/A	7.60	Pass
<b>ortho-Phosphate (as P) - unspecified mg/l</b>	1	1.2	N/A	6	5	5	2.47	Fail
<b>Dissolved Inorganic Nitrogen (as N) mg/l</b>	N/A	N/A	N/A	6	N/A	N/A	23	
<b>Total Oxidised Nitrogen (as N) mg/l</b>	N/A	N/A	N/A	6	N/A	N/A	0.707	

Parameter	WWDL ELV (Schedule A)	ELV with Condition 2 Interpretation included Note 1	Interim % reduction from influent concentration	Number of sample results	Number of exceedances	Number of exceedances with Condition 2 Interpretation included	Annual Mean	Overall Compliance (Pass/Fail)
<b>Total Phosphorus (as P) mg/l</b>	N/A	N/A	N/A	1	N/A	N/A	6.56	
<b>Total Nitrogen mg/l</b>	N/A	N/A	N/A	1	N/A	N/A	52	

Notes:

1 – This represents the Emission Limit Values after the Interpretation provided for under Condition 2 of the licence is applied

2 – For pH the WWDA specifies a range of pH 6 - 9

### Cause of Exceedance(s):

Refer to Incident Section of Report

### Significance of Results:

The WWTP is non compliant with the ELV's set in the wastewater Discharge License. The impact on receiving waters is assessed further in Section2.

## 2.1.3 AMBIENT MONITORING SUMMARY FOR THE TREATMENT PLANT DISCHARGE TPEFF1900D0315SW001

A summary of monitoring from ambient monitoring points associated with the wastewater discharge is provided in the sections below. For discharges to rivers upstream (U/S) and downstream (D/S) location data is provided. For other ambient points in lakes, coastal or transitional waters, monitoring data from the most appropriate monitoring station is selected.

The table below provides details of ambient monitoring locations and details of any designations as sensitive areas.

Ambient Monitoring Point from WWDL (or as agreed with EPA)	Irish Grid Reference	River Station Code	Bathing Water	Drinking Water	FWPM	Shellfish	WFD Ecological Status
Upstream	133883, 150742	RS24D021450	No	No	No	No	Good
Downstream	133883, 150742	RS24D021400	No	No	No	No	Good

The table below provides a summary of monitoring results for designated ambient monitoring points. The upstream and downstream annual mean values are shown (mg/l), and the difference between both monitoring stations is given as a percentage of the Environmental Quality Standard (EQS) where relevant.

Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
BOD - 5 days (Total) mg/l	RS24D021450	1.78	RS24D021400	1.65	1.50	-8.6
Ammonia-Total (as N) mg/l	RS24D021450	0.035	RS24D021400	0.037	0.065	3
ortho-Phosphate (as P) - unspecified mg/l	RS24D021450	0.074	RS24D021400	0.083	0.035	23.4
True Colour mg/litre Pt Co	RS24D021450	29	RS24D021400	36	N/A	
Total Hardness (as CaCO <sub>3</sub> ) mg/l	RS24D021450	474	RS24D021400	414	N/A	
Dissolved Oxygen % Saturation	RS24D021450	96	RS24D021400	98	N/A	
Alkalinity-total (as CaCO <sub>3</sub> ) mg/l	RS24D021450	208	RS24D021400	216	N/A	
Nitrite (as N) µg/l	RS24D021450	8.84	RS24D021400	12	N/A	



Parameter Name	Upstream Monitoring Point Location	Upstream Monitoring Point Annual Mean	Downstream Monitoring Point Location	Downstream Monitoring Point Annual Mean	EQS	% of EQS
<b>Total Oxidised Nitrogen (as N) mg/l</b>	RS24D021450	1.66	RS24D021400	1.57	N/A	
<b>Temperature °C</b>	RS24D021450	11	RS24D021400	12	N/A	
<b>pH pH units</b>	RS24D021450	8.04	RS24D021400	8.09	N/A	
<b>Dissolved Oxygen mg/l</b>	RS24D021450	11	RS24D021400	11	N/A	
<b>Conductivity @25°C µS/cm</b>	RS24D021450	2808	RS24D021400	2077	N/A	
<b>Chloride mg/l</b>	RS24D021450	779	RS24D021400	540	N/A	
<b>Nitrate (as N) mg/l</b>	RS24D021450	2.08	RS24D021400	1.68	N/A	

### Significance of Results:

The WWTP discharge was not compliant with the ELV's set in the wastewater discharge licence.

The ambient monitoring results do not meet the required EQS at the upstream and the downstream monitoring locations. The EQS relates to the Oxygenation and Nutrient Conditions set out in the Surface Water Regulations 2009.

Based on ambient monitoring results a deterioration in Ammonia and Ortho-Phosphate., concentrations downstream of the effluent discharge is noted.

The discharge from the wastewater treatment plant does not have an observable negative impact on the Water Framework Directive status.

## 2.1.4 OPERATIONAL PERFORMANCE SUMMARY - ASKEATON WWTP

### 2.1.4.1 Treatment Efficiency Report - Askeaton WWTP

Treatment efficiency is based on the removal of key pollutants from the influent wastewater by the treatment plant. In essence the calculation is based on the balance of load coming into the plant versus the load leaving the plant. The efficiency is presented as a percentage removal rate.

A summary presentation of the efficiency of the treatment process including information for all the parameters specified in the licence is included below:

Parameter	Influent mass loading (kg/year)	Effluent mass emission (kg/year)	Efficiency (% reduction of influent load)
TN	9715	10003	-2.96
COD	38234	32591	15
TP	1154	1257	-8.97
cBOD	17649	14487	18
SS	14057	11069	21

Note: The above data is based on sample results for the number of dates reported

### 2.1.4.2 Treatment Capacity Report Summary - Askeaton WWTP

Treatment capacity is an assessment of the hydraulic (flow) and organic (the amount of pollutants) load a treatment plant is designed to treat versus the current loading of that plant.

Askeaton WWTP	
Peak Hydraulic Capacity (m <sup>3</sup> /day) - As Constructed	411
DWF to the Treatment Plant (m <sup>3</sup> /day)	137
Current Hydraulic Loading - annual max (m <sup>3</sup> /day)	718

Askeaton WWTP	
Average Hydraulic loading to the Treatment Plant (m <sup>3</sup> /day)	252
Organic Capacity (PE) - As Constructed	550
Organic Capacity (PE) - Collected Load (peak week) <sup>Note1</sup>	1426
Organic Capacity (PE) - Remaining	0
Will the capacity be exceeded in the next three years? (Yes/No)	Yes

Nominal design capacities can be based on conservative design principles. In some cases assessment of existing plants has shown organic capacities significantly higher than the nominal design capacity. Accordingly plants that appear to be overloaded when comparing a collected peak load with the nominal design capacity can be fully compliant due to the safety factors in the original design.

## 2.1.5 SLUDGE / OTHER INPUTS - ASKEATON WWTP

'Other inputs' to the waste water treatment plant are summarised in table below

Input type	Quantity	Unit	P.E.	% of load to WWTP	Included in Influent Monitoring (Y/N)?	Is there a leachate/sludge acceptance procedure for the WWTP?	Is there a dedicated leachate/sludge acceptance facility for the WWTP? (Y/N)
There is no Sludge and Other Input data for the Treatment Plant included in the AER.							

## 3 COMPLAINTS AND INCIDENTS

### 3.1 COMPLAINTS SUMMARY

A summary of complaints of an environmental nature related to the discharge(s) to water from the WWTP and network is included below.

Number of Complaints	Nature of Complaint	Number Open Complaints	Number Closed Complaints
There were no relevant environmental complaints in 2022.			

### 3.2 REPORTED INCIDENTS SUMMARY

Environmental incidents that arise in an agglomeration are reported on an on-going basis in accordance with our waste water discharge licences. Where an incident occurs and it is reportable under the licence, it is reported to the Environmental Protection Agency through their Environmental Data Exchange Network, or in some instances by telephone. Some incidents which arise in the agglomeration are recorded by Uisce Éireann but may not be reportable under our licence for example where the incident does not have an impact on environmental performance.

A summary of reported incidents is included below.

#### 3.2.1 SUMMARY OF INCIDENTS

Incident Type	Cause	No. of incident occurrences	Recurring (Y/N)	Closed (Y/N)
Breach of ELV	WWTP upgrade required to meet ELV	1	Yes	No
Uncontrolled release	Network Infrastructure	1	Yes	No
Uncontrolled release	EO caused by pump failure	1	Yes	No

### 3.2.2 SUMMARY OF OVERALL INCIDENTS

Question	Answer
Number of Incidents in 2022	3
Number of Incidents reported to the EPA via EDEN in 2022	3
Explanation of any discrepancies between the two numbers above	N/A

## 4 INFRASTRUCTURAL ASSESSMENTS AND PROGRAMME OF IMPROVEMENTS

### 4.1 STORM WATER OVERFLOW IDENTIFICATION AND INSPECTION REPORT

A summary of the operation of the storm water overflows and their significance where known is included below:

#### 4.1.1 SWO IDENTIFICATION

WWDL Name / Code for Storm Water Overflow (chamber) where applicable	Irish Grid Ref. (outfall)	Included in Schedule of the WWDL	Significance of the overflow(High / Medium / Low)	Assessed against DoEHLG Criteria	No. of times activated in 2022 (No. of events)	Total volume discharged in 2022 (m3)	Monitoring Status
SW-2	134015,150298	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
SW-3	134107,150271	Yes	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored
TBC	134093,150439	No	Low Significance	Meeting Criteria	Unknown	Unknown	Not Monitored

Any TBC SWO(s) were identified as part of the on-going National SWO programme and will be updated in subsequent AER(s) once the information is confirmed.

SWO Summary	
How much sewage was discharged via monitored SWOs in the agglomeration in the year (m3)?	Unknown
Is each SWO identified as not meeting DoEHLG Guidance included in the Programme of Improvements?	N/A
The SWO Assessment included the requirements of relevant of WWDL schedules?	Yes

## SWO Summary

Have the EPA been advised of any additional SWOs / changes to Schedule C3 and A4 under Condition 1.7?

N/A

## 4.2 REPORT ON PROGRESS MADE AND PROPOSALS BEING DEVELOPED TO MEET THE IMPROVEMENT PROGRAMME REQUIREMENTS.

### 4.2.1 SPECIFIED IMPROVEMENT PROGRAMME SUMMARY

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Specified Improvement Programmes (under Schedule A and C of WWDL)	Description	Licence Schedule	Licence Completion Date	Date Expired? (N/NA/Y)	Status of Works	Timeframe for Completing the Work	Comments
<b>D0315-SIP:01</b>	New pumping station and storm-water storage capacity	C	01/01/2014	No	At Planning Stage	2029	
<b>D0315-SIP:02</b>	New waste water treatment plant and ancillary works	C	01/01/2014	Yes	At Planning Stage	2029	
<b>D0315-SIP:03</b>	SW-1 to be discontinued when discharge from SW4 commences	A	31/12/2020	Yes	At Planning Stage	2029	

A summary of the status of any other improvements identified by under Condition 5 assessments- is included below.

## 4.2.2 IMPROVEMENT PROGRAMME SUMMARY

Improvement Identifier	Improvement Description / or any Operational Improvements	Improvement Source	Expected Completion Date	Comments
<b>No additional improvements planned at this time.</b>				

## 4.2.3 SEWER INTEGRITY RISK ASSESSMENT

The utilisation of multiple capital maintenance programmes and the outputs of the workshops with the Local Authority Operations Staff held under the programme can be used to satisfy the requirements of Condition 5 regarding network integrity. Improvement works identified by way of these programmes and workshops will be included in the Improvements Summary Tables 4.2.1 and 4.2.2.



## 5 LICENCE SPECIFIC REPORTS

A wastewater discharge licence may require a number of reports on specific subject areas to be prepared for the agglomeration in question. These reports are submitted to the EPA as part of the Annual Environmental Report. This section provides a list of the various reports required for this agglomeration and a brief summary of their recommendations.

Licence Specific Report	Required by licence	Year included in AER	Included in this AER
<b>There is no Licence Specific Report Required in this AER Annual Review.</b>			

## 6 CERTIFICATION AND SIGN OFF

### 6.1 SUMMARY OF AER CONTENTS

Parameter	Answer
Does the AER include an Executive Summary?	Yes
Does the AER include an assessment of the performance of the Waste Water Works (i.e. have the results of assessments been interpreted against WWDL requirements and or Environmental Quality Standards)?	Yes
Is there a need to advise the EPA for Consideration of a Technical Amendment/Review of the Licence?	Yes
List reason e.g. additional SWO identified	Additional SWO identified
Is there a need to request/advise the EPA of any modification to the existing WWDL with respect to condition 4 changes to monitoring location, frequency etc	Yes
List reason e.g. changes to monitoring requirements	Ambient Monitoring Location Changes
Have these processes commenced?	No
Are all outstanding reports and assessments from previous AERs included as an appendix to this AER	N/A

I certify that the information given in this Annual Environmental Report is truthful, accurate and complete:

Signed:    Date: 14/04/2023

This AER has been produced by Uisce Éireann's Environmental Information System (EIMS) and has been electronically signed off in that system for and on behalf of ,

Eleanor Roche

Acting Head of Environmental Regulation.

## **7 APPENDIX**

There are no Appendices included